



July 15, 2026

**Addendum #1
for RFP No. CSD 26-01
Backup Generator SG Nesbitt Memorial Arena**

This addendum shall be incorporated into and form part of RFP No. CSD 26-001 for RFP No. RDS 26-002 Backup Generator SG Nesbitt Memorial Arena.

Receipt of the Addendum shall be acknowledged as part of your submission as per Section 2.14 – Addenda of the RFP document and **must be included** in the submission package before the closing date of **July 20, 2026 at 4:00pm**.

The Township of Minden Hills reserves the right to reject any or all tenders or accept any proposal, should it deem such actions to be in the best interest of the Township.

Please note the following changes to the RFP deadlines:

Final Day for Submission July 20, 2026 at 4:00pm.

Public Opening July 22 at 12:30pm

Question period closes July 17 2026 at 4:00pm

Question #1: Does this generator installation need to meet CSA 282?

Answer #1: Yes, this generator installation will need to meet CSA 282.

This addendum consists of 2 pages.

If you have questions regarding this matter, please contact the Township directly as outlined in Section 2.13 – Inquiries of the RFP document.

Sincerely,

Candace McGuigan
Director of Community Services

Acknowledgement of Receipt

Bidders are required to acknowledge receipt of all addenda by signing the Acknowledgement of Receipt below. Failure to submit all addenda will constitute an automatic rejection.

I/we hereby acknowledge receipt of this addendum and make allowances in my bid.

Signature of Bidder

Date

Name of Company